



CITY OF PLAINVILLE
PROPOSED WELL LOCATION
NW4 SECTION 27
TOWNSHIP 7 SOUTH, RANGE 18 WEST
ROOKS COUNTY, KANSAS

R3903.1
PAGE 1 OF 3



PROPERTY OWNER: CITY OF PLAINVILLE

BASE FLOOD ELEVATION AS DETERMINED BY U.S. ARMY CORPS OF ENGINEERS, TULSA DISTRICT IN A LETTER DATED 3 FEBRUARY, 2021.

BASE FLOOD ELEVATION - 1782.6 FEET (NAVD 88)

FINISH FLOOR ELEVATION OF PROPOSED CONCRETE PAD IS 1779.0

THE LOWEST EXISTING GROUND ELEVATION IS 1777.0.


DATUM BENCHMARK - NGS TRI-STATION "STOCK 1950".

TEMPORARY BENCHMARK - CHISELED "+" AT NEC OF CONCRETE SLAB OF EXISTING WELL #19.
ELEVATION - 1777.55

NOTE THIS SKETCH IS FOR THE SOLE PURPOSE OF APPLYING FOR DWR FILL PERMIT. THIS SKETCH IS NOT TO BE USED FOR BOUNDARY SURVEY PURPOSES.

CITY OF PLAINVILLE
PROPOSED WELL LOCATION
NW4 SECTION 27
TOWNSHIP 7 SOUTH, RANGE 18 WEST
ROOKS COUNTY, KANSAS

R3903.1
PAGE 2 OF 3



PROPERTY OWNER: CITY OF PLAINVILLE

BASE FLOOD ELEVATION AS DETERMINED BY U.S. ARMY CORPS OF ENGINEERS, TULSA DISTRICT IN A LETTER DATED 3 FEBRUARY, 2021.

BASE FLOOD ELEVATION - 1782.6 FEET (NAVD 88)

FINISH FLOOR ELEVATION OF PROPOSED CONCRETE PAD IS 1779.0

THE LOWEST EXISTING GROUND ELEVATION IS 1777.0.

DATUM BENCHMARK - NGS TRI-STATION "STOCK 1950".


TEMPORARY BENCHMARK - CHISELED "+" AT NE CORNER OF CONCRETE SLAB OF EXISTING WELL #19.
ELEVATION - 1777.55

NOTE THIS SKETCH IS FOR THE SOLE PURPOSE OF APPLYING FOR DWR FILL PERMIT. THIS SKETCH IS NOT TO BE USED FOR BOUNDARY SURVEY PURPOSES.


EVANS-BIERLY-HUTCHISON & ASSOCIATES P.A.
1105 WILLIAMS STREET, GREAT BEND, KS 67530 | (620) 793-8411

CITY OF PLAINVILLE
PROPOSED WELL LOCATION
NW4 SECTION 27
TOWNSHIP 7 SOUTH, RANGE 18 WEST
ROOKS COUNTY, KANSAS

R3903.1
PAGE 3 OF 3



WEST/EAST CROSS SECTION
PROPOSED WELL PAD



NORTH/SOUTH CROSS SECTION
PROPOSED WELL PAD

PROPERTY OWNER: CITY OF PLAINVILLE

BASE FLOOD ELEVATION AS DETERMINED BY U.S. ARMY CORPS OF ENGINEERS, TULSA DISTRICT IN A LETTER DATED 3 FEBRUARY, 2021.

BASE FLOOD ELEVATION - 1782.6 FEET (NAVD 88)

FINISH FLOOR ELEVATION OF PROPOSED CONCRETE PAD IS 1779.0

THE LOWEST EXISTING GROUND ELEVATION IS 1777.0.

DATUM BENCHMARK - NGS TRI-STATION "STOCK 1950".

TEMPORARY BENCHMARK - CHISELED "+" AT NE_C OF CONCRETE SLAB OF EXISTING WELL #19.
ELEVATION - 1777.55

NOTE THIS SKETCH IS FOR THE SOLE PURPOSE OF APPLYING FOR DWR FILL PERMIT. THIS SKETCH IS NOT TO BE USED FOR BOUNDARY SURVEY PURPOSES.

EVANS-BIERLY-HUTCHISON & ASSOCIATES P.A.
1105 WILLIAMS STREET, GREAT BEND, KS 67530 | (620) 793-8411